### TEMPERATURE TRANSMITTER

Type: Ex for zone 0, 1 or 2, EEx ia IIC

T1...T6, programmable Input: RTD, Ohm

Type: TT-5333D Sheet No. 6-5 V2.1

10122-E010818V2.1



## Application:

- Temperature linearised measurement with Pt100...Pt1000 or Ni100...Ni1000.
- Conversion of linear resistance change to standard analogous current signal, e.g. from valves or ohmic level sensors

#### Properties:

- High measurement accuracy
- RTD- 2 or 3conductor attachment
- The RTD and resistance inputs have cable compensation for 2-, 3and 4-conductor attachments
- Programmable sensor error value
- Can be programmed within a few seconds by 2-way configuration (Windows), to measure temperatures within all RTD ranges defined by the norms
- TAG No: 15 character configurable
- Degree of protection (case/clamp): IP68 / IP00
- Measurements: Ø44 x 20.2mm
- Mounting/ installation: can be mounted in DIN form B sensor head or on DIN track with special clamp



### **TECHNICAL DATA:**

#### **INPUT:**

Туре	Min temp.	Max temp.	Min span	Norm
Pt100	-200°C	+850°C	25°C	DIN IEC 751
Ni100	-60°C	+250°C	25°C	
Lin. R	Ω0	10000ohm	30ohm	

### **COMMUNICATION INTERFACE:**

Loop link 5905

## **MECHANICAL DATA:**

Measurements: Ø 44 x 20,2 mm

Degree of protection (case/clamp): IP68/ IP100

### **ENVIROMENTAL CONDITIONS:**

Operating temperature: -40°C to +85°C Humidity: < 95% RH (non-cond.)

#### **TECHNICAL DATA:**

o		т	О		т	٠.
v	u		г	u		

Signal range: ...... 4 - 20 mA

#### **ACCURACY:**

Type:	Basic	Temperature
	accuracy:	coefficient:
RTD	<±0,2°C	<±0,01°C/°C
LIN R	<±0,10hm	<±10mohm/°C

### **COMMON SPECIFICATIONS:**

Supply voltage: DC: 7,2...35 V

Voltage drop: 7,2 VDC

Reaction time (programmable): 0,33...60 s

### **SENSOR TROUBLE SHOOTING:**

Programmable: 3.5...23 mA NAMUR NE43 Upscale: 23 mA NAMUR NE43 Downscale: 3,5 mA

Ordering details: Please state If the transmitter

should be programmed

Transmitter Input Type:			
4 mA =	C°	20 mA =	C°





# 2-wire programmable transmitter

## 5333D

- RTD or Ohm input
- High measurement accuracy
- 3-wire connection
- Programmable sensor error value
- For DIN form B sensor head mounting

























#### **Application**


- · Linearized temperature measurement with Pt100...Pt1000 or Ni100...Ni1000 sensor.
- · Conversion of linear resistance variation to a standard analog current signal, for instance from valves or Ohmic level sensors.

#### **Technical characteristics**

- Within a few seconds the user can program PR5333D to measure temperatures within all RTD ranges defined by the
- · The RTD and resistance inputs have cable compensation for 3-wire connection.

### Mounting / installation

· For DIN form B sensor head mounting.



**Type** 5333D

### **Environmental Conditions**

Operating temperature	-40°C to +85°C
Calibration temperature	2028°C
Relative humidity	< 95% RH (non-cond.)
Protection degree (encl./terminal)	IP68 / IP00

## **Mechanical specifications**

Dimensions	Ø 44 x 20.2 mm
Weight approx	50 g
Wire size	1 x 1.5 mm <sup>2</sup> stranded wire
Screw terminal torque	0.4 Nm
Vibration	IEC 60068-2-6
225 Hz	±1.6 mm
25100 Hz	±4 g

### **Common specifications**

Supply Supply voltage Internal power dissipation	
Response time (programmable)	0.3360 s

Response time (programmable)	0.3360 s
Voltage drop	5 min. Loop Link Min. 60 dB Better than 0.1% of sel. range 19 bit 16 bit < 0.005% of span / VDC
,	

## Input specifications

Common input specifications Max. offset	50% of selected max. value
RTD type	Dt100 Ni100 lin D
Cable resistance per wire	The state of the s

Linear resistance input

Linear resistance min...max..... 0  $\Omega$ ...10000  $\Omega$ 

## **Output specifications**

Current output	
Signal range	420 mA
Min. signal range	
Load (@ current output)	$\leq$ (Vsupply - 8) / 0.023 [ $\Omega$ ]
Load stability	≤ 0.01% of span / 100 Ω
Sensor error indication	Programmable 3.523 mA
NAMUR NE43 Upscale/Downscale	23 mA / 3.5 mA
Common output specifications	
Updating time	135 ms
of span	= of the presently selected range

## Observed authority requirements

EMC	2014/30/EU
FAC	TR-CU 020/2011

### **Approvals**

• •	
ATEX	KEMA 03ATEX1535 X
IECEx	DEK 13.0036X
FM	FM17US0013X
CSA	. 1125003
INMETRO	. DEKRA 16.0014 X
EAC Ex	. RU C-DK.GB08.V.00410
DNV-GL Marine	Stand. f. Certific. No. 2.4